

## **Advanced Evaporative Cooling Eligibility Details**

- New cooling equipment make/model/size (tons)
- Existing cooling equipment replaced make/model/size (tons)/age/efficiency
- Equipment must be permanently installed
- Equipment must be indirect, hybrid, or two-stage evaporative cooling unit. Portable coolers or systems with vapor compression backup are not eligible
- A minimum Media Saturation Effectiveness of 85% is required
- Units must be installed with a remote thermostat and a periodic purge water control
- Facility type (same as round 1 lighting list)