

HVAC Eligibility Details

- Hot Water Boilers (condensing, for space heating and domestic water only):
 - Rebates will be offered for new equipment only
 - Must be a replacement of currently operating equipment with an efficiency gain of >15%
 - Boilers must meet minimum efficiency of 92% AFUE
 - Back-up equipment not eligible for rebates
 - Customer must provide CO State inspection report with application
- Air-side Economizers:
 - Economizer shall provide first stage cooling
 - Mechanical cooling will start at second stage
 - Economizer control shall include an outside air temperature sensor
 - Any size air-handling unit will qualify
- Water or Ground Source Heat Pump:
 - Installer must be IGSPHA certified, closed loop only
- Roof Top AC Units:
 - Rebates will be offered for new equipment only
 - Replacement of currently operating equipment
 - New equipment must be currently rated at AHRI standards. For a list of qualified equipment see: <http://www.ahridirectory.org/ahridirectory/pages/home.aspx>
 - Equipment must be less than 19.9 tons
 - Equipment less than 5.4 tons must be minimum 14 SEER
 - Equipment between 5.5 and 19.9 tons must be minimum 11.5 SEER
 - Equipment must use a minimum ozone-depleting refrigerant such as R-22, R-123, and R-134
 - Refer to Consortium of Energy Efficiency for listing of Tier 1 and Tier 2 equipment (<http://www.cee1.org/com/hecac/hecac-tiers.pdf>)
- Split Systems:
 - Rebates will be offered for new equipment only
 - Replacement of currently operating equipment
 - New equipment must be currently rated at AHRI standards. For a list of qualified equipment see: <http://www.ahridirectory.org/ahridirectory/pages/home.aspx>
 - Equipment must be less than 5.4 tons and must be minimum 14 SEER
 - Condensing unit and coil must both be newly installed to receive a rebate. Efficiencies will be based on the condensing unit and coil combination rated by AHRI.
 - Equipment must use a minimum ozone-depleting refrigerant such as R-22, R-123, and R-134
- Furnace:
 - Rebates will be offered for new equipment only
 - Replacement of currently operating equipment
 - Furnaces must meet minimum efficiency of 92% AFUE with an efficiency gain of >15%
- Ground or Water Source Heat Pump:
 - Must be installed by IGSHHP certified installer
- Re-Commissioning:
 - Retro-Commissioning of commercial HVAC systems
- Controls:
 - Proper design and installation of HVAC control technologies. Must be hard-wired to qualify